



- NOTE:
- 1.) DIMENSIONS SHOWN ARE INSIDE MEASUREMENTS OF PIT.
 - 2.) ALL PIPE SHALL BE FLANGED END DUCTILE CAST IRON (CL-51).
 - 3.) ALL VALVES SHALL BE FLANGED END, HANDWHEEL OPERATED, RISING STEM, OS&Y RESILIENT WEDGE - ALL MUST OPERATE IN THE SAME DIRECTION.
 - 4.) PIT WORKING HEIGHT INSIDE - 6' MINIMUM.
 - 5.) ALL PIPE MUST HAVE MINIMUM 48" COVER AND 18" MINIMUM FROM FLOOR
 - 6.) WALLS TO BE FORMED CONCRETE OR PRE-CAST
 - 7.) CONCRETE FLOOR WITH 2'x2'x2' SUMP PIT AND PERMANENT SUMP PUMP WITH MINIMUM DISCHARGE OF 500 G.P.H.
 - 8.) PIPING AND METER MUST BE ADEQUATELY SUPPORTED WITH CONCRETE PIPE SUPPORTS.
 - 9.) ALTERNATE DESIGN MAY BE SUBMITTED FOR REVIEW.
 - 10.) METER FLANGED END MUST BE UNI-FLANGED
 - 11.) 1/2" HOLE REQUIRED IN METER PIT ACCESS DOOR /LID FOR HAZARDOUS GAS TESTING. PROVIDE 1 7/8" DIA. HOLES IN DOOR FOR INSTALLATION OF REMOTE READ PAD FOR EACH METER.
 - 12.) METER ONE SIZE SMALLER THAN PIPING MAY BE INSTALLED USING REDUCERS BEFORE AND AFTER METER.
 - 13.) METER SHALL BE SUPPLIED BY COUNTY TO CONTRACTOR TO BE INSTALLED WITH OTHER PIPING FOR PROPER ALIGNMENT. METER TO BE INSTALLED IN CENTER OF METER SPREAD.
 - 14.) TOP SLAB OF METER PIT TO BE INSTALLED AFTER INSTALLATION OF MASTER METER

**NOTE: BACKFLOW PREVENTION DEVICE AS SPECIFIED BY MONTGOMERY COUNTY WATER SERVICES WILL BE REQUIRED AT SERVICE ENTRANCE

MONTGOMERY COUNTY
WATER SERVICES



MASTER METER PIT
INSTALLATION
8" SERVICE LINE
(FOR OFF ROAD USE ONLY)

Revised ~ 11/26/08

SCALE : NONE

DATE : 11/01/06

FILE NAME: 8MTRPIT