


- NOTES:
1. ALTERNATE DESIGNS MAY BE SUBMITTED TO MCES FOR APPROVAL.
 2. CONTRACTOR TO SUPPLY ALL MATERIALS UNLESS OTHERWISE NOTED.
 3. FOR COMMERCIAL APPLICATIONS, REDUCED PRESSURE ZONE (ASSE 1013) BACKFLOW DEVICE REQUIRED AT SERVICE ENTRANCE.
 4. FOR IRRIGATION OR WATER ONLY METER INSTALLATIONS, REDUCED PRESSURE ZONE (ASSE 1013) BACKFLOW DEVICE REQUIRED ABOVE GRADE IMMEDIATELY AFTER METER.
 5. BACKFLOW PREVENTION TO BE IN ACCORDANCE WITH MCES RULES AND REGULATIONS AND OHIO PLUMBING CODE.
 6. SEE STANDARD DETAILS FOR SINGLE WATER METER INSTALLATIONS FOR MORE INFORMATION.



MONTGOMERY COUNTY
ENVIRONMENTAL SERVICES

**STANDARD INSTALLATION
FOR IRRIGATION/WATER
ONLY METERS
(FOR OFF ROAD USE ONLY)**

SCALE : NONE

DATE : 2/11/2020